

# Classification Report on Reaction to Fire of Construction Products

Nr. 17-001714-PR02  
(KB-K02-01-en-01)



Client **NORD RESINE SPA**  
**Via Fornace Vecchia 79**  
**31058 Susegana (TV)**  
**Italy**

Notified Body **ift Rosenheim GmbH**  
**Theodor-Gietl-Straße 7-9**  
**D-83026 Rosenheim**

Notified Body No. **0757**

Issue No. **1**

Object **Sealant**

Designation **"BETONSEAL MS 2.0"**

## Basis

DIN EN 13501-1:2010-01  
Fire classification of construction products and building elements.  
Part 1: Classification using test data from reaction to fire tests  
Test reports:  
17-001714-PR03 (PB-K02-01-de-01)  
17-001714-PR01 (PB-K02-09-en-01)

## Instruction for use

This classification report for reaction to fire defines the classification assigned to the building material according to its product designation in conformity with the methods set out by DIN EN 13501-1.

This document does not represent type approval or certification of the product.

## Validity

The data and results given relate solely to the tested and described specimen.

## Notes on publication

The ift Guidance Sheet „Conditions and Guidance for the Use of ift Test Documents“ applies. No part of this document may be used or reproduced as an extract.

## Contents

The report comprises a report of 6 pages.

- 1 Introduction
- 2 Details of classified product
- 3 Test reports and test and test results to justify this classification
- 4 Classification and direct field of application
- 5 Restrictions



Classification of reaction to fire  
DIN EN 13501-1

**Class E**

ift Rosenheim  
09.01.2018



*Gerhard Wackerbauer*

Dr. Gerhard Wackerbauer, Dipl. Phys.  
Head of Testing Department  
Fire Safety

Dr. rer.nat. Mihaela Buschbeck  
Operating Testing Officer  
Fire Safety